

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No Dist/Lab/July 2024-970-119

Dated: 24-07-2024.

It is certified that an inspection team headed by **Raman Kumar Jha Lab Asst.** (Name of Officers with designation) from **P. H. E. D. DIVISION, MADHUBANI** (Name of Department/ Office) inspected the **VIVEK INTERNATIONAL RESIDENTIAL SCHOOL, VIDYANAGAR, GIDHVAS, KHAJEDIH, LADANIYA MADHUBANI, BIHAR.**

(Name & Address of the school) on **23/07/2024** (date of inspection) and found that the **VIVEK INTERNATIONAL RESIDENTIAL SCHOOL** (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/State/ U.T. Govt.

The above is valid for a period of One Year

Signature with Seal:

Name :- GAURAV SRIVASTAVA

Designation :- ASSISTANT ENGINEER

Bihar Govt. Public Health Engineering Department

(PHED) Madhubani/Authorised officer of the local Body


(Name & Address of the Office /Department:)

To

VIVEK INTERNATIONAL RESIDENTIAL SCHOOL, VIDYANAGAR

GIDHVAS, KHAJEDIH, LADANIYA MADHUBANI, BIHAR

(Name & Address of the Institution)


24/07/24
S.D.O.
P.H. Sub-Division
Madhubani

**DISTRICT LEVEL WATER TESTING LABORATORY
P.H.DIVISION, MADHUBANI**

date of sampling-23/07/2024
date of testing-24/07/2024
month-JULY 2024

| Sl No. | Block | Panchayat | Village | Habitation | Name of Location/ Nearest Person | PH. | Tub. | T.H | T.A | Ca | Mg | Cl | Fe | F | SO4 | NO3 | TDS | EC | AS | MPN | Remarks |
|---------------------------|----------|-----------|----------|------------|-------------------------------------------------|-----------|--------|-----------|-----------|----------|----------|------------|-----|-----------|-----------|-----|------------|-----|-----------|-----|---------|
| 1 | Ladaniya | Gidhvas | Khajadih | Vidyanagar | Vivek InterNatio NatoinResidential School | 7.3 | 2 | 260 | 280 | 38 | 53.2 | 40 | 0.3 | 0.1 | nil | 0 | 278 | 425 | NT | A | |
| Min-Max-Permissible Limit | | | | | | 6.5 - 8.5 | 1.0-05 | 200 - 600 | 200 - 600 | 75 - 200 | 30 - 100 | 250 - 1000 | 1.0 | 0.5 - 1.5 | 200 - 400 | 45 | 500 - 2000 | | 0.01 - NR | | |

*A - Absent
*NT - Not Tested
*BDL- Below Detection Limit

P. B. D. Madhubani
Chemist/Lab. Assistant
District Laboratory Madh
P. B. D. Madhubani